

Contains No CBI

RECEIVED
OPPT CBIC

U.S. Environmental Protection Agency Meeting Summary 05 MAR 22 PM 3:02

May 7, 2004

**PFOA ECA Fluoropolymer Technical Workgroup Meeting Summary
3/31/04**

Sixty-two participants: Attendance list, presentation materials, and additional information provided at the meeting is in the docket at OPPT-2003-0012-0528 through 0536, and at 0544.

The meeting included five sections:

- I. Fluoropolymer Incineration ECA Update
- II. Fluoropolymer Aged Articles ECA Subgroup Report
- III. Status of Fluoropolymer Dispersion Processors Material Balance Study
- IV. Fluoropolymer Monitoring Update
- V. Identification of Workgroup Next Steps

I. Fluoropolymer Incineration ECA Update

ECA Drafting Committee Presentation

Rich Leukroth of EPA began by introducing George Semeniuk of EPA, who will be leading the EPA drafting work on the monitoring Memoranda of Understanding (MOUs). Mr. Leukroth then presented an update on behalf of the Incineration ECA Drafting Committee on progress made in development of an Enforceable Consent Agreement (ECA) for incineration testing of fluoropolymers. The presentation included a list of the Incineration ECA Drafting Committee members, a summary of recent drafting committee activities, an update on public comments on the ECA, an update on the status of Appendix F, a report on the fulfillment of the request for chemical specific data, a report on the conclusion of the Drafting Committee's work, a proposed recommendation to the Plenary, and next steps. The presentation is in the docket at OPPT-2003-0012-0529.

Discussion

The workgroup agreed to recommend to the Plenary that the Final Draft ECA for the Laboratory-Scale Incineration Testing of Fluoropolymers be approved by the Plenary and executed by EPA. The companies that have not yet submitted complete information on the chemicals to be tested were directed to submit that information.

II. Fluoropolymer Aged Articles ECA Subgroup Report

Subgroup Presentation

George Millet of Dyneon gave an update from the Aged Articles of Commerce (AAOC) Expert Subgroup. The presentation included information on the establishment and activities of the Equipment Design Team, steps toward ECA drafting, extraction solvent selection, articles of commerce to be tested, testing structure, aged article use and test conditions, and the path forward. The presentation is in the docket at OPPT-2003-0012-0530.

05 MAR 22 PM 3:02

RECEIVED
OPPT CBIC



00:38 PM 18 MAR 2005

RECEIVED
OPPT NCIC

MR 28487 284707

Discussion

EPA asked what the timing for the ECA development would be. The response was that it is difficult to project. EPA requested that the Subgroup consult among its members and present at least a rough draft schedule in the report to be made to the Plenary.

III. Status of Fluoropolymer Dispersion Processors Material Balance Study

FMG Presentation

David Sarvadi of Keller and Heckman, representing SPI, presented an update on the fluoropolymer Dispersion Processors Material Balance (DPMB) study, which is part of the FMG LOI commitment. The presentation included information on the study purpose, processor selection criteria, processor category vs processing temperature, DPMB study progress, and a chart showing a material balance report example. The presentation is in the docket at OPPT-2003-0012-0531. Mr. Sarvadi also presented EPA with a CD containing an electronic copy of the DPMB study Quality Assurance Project Plan (QAPP), which appears in the docket with its accompanying transmittal letter at OPPT-2003-0012-0535 and 0536.

Discussion

Questions arose regarding the types of processes, number of samples, and percent of industry represented. FMG responded the participants in the study represent segments that account for half of the ammonium perfluorooctanoate (APFO) used in dispersion products, based on volume in pounds.

An interested party asked whether and how fugitive emissions would be taken into consideration in the material balance report. FMG replied that it expects fugitive emissions will be included in the air analysis.

IV. Fluoropolymer Monitoring Update

FMG Presentation

Mike Santoro of 3M provided an update on 3M's proposed monitoring program for the fluoropolymer manufacturing segment. The presentation included the approach to program development, elements of the phased approach, 3M LOI commitments (Phase I), elements of Phase II, revisions to the February 16 Work Plan submittal, assessment reports, a summary of the monitoring program, and Phase II tentative schedule. The presentation also included an acknowledgment from 3M and DuPont that there will be a Phase III program. The presentation is in the docket at OPPT-2003-0012-0532. DuPont and 3M also presented proposed peer

consultation charge clarification language, which appears in the docket at OPPT-2003-0012-0533.

Discussion

EPA expressed concern that 3M's proposed monitoring centered around human routes of exposure and noted that EPA stated that characterization of the presence in environmental media (including biota) was clearly within the scope of this effort as described in the Preliminary Framework document and the Federal Register notice, as well as EPA's subsequent data needs document.

EPA asked if 3M anticipated any issues with sampling at the city municipal authority. 3M responded that they have a good relationship with the city and do not foresee any problems.

Questions were raised regarding the details, such as depth, of the sampling of soils in the areas of LOI wells. 3M stated that the details will be spelled out in the Work Plan and a detailed Work Plan should be available early in the week of April 5, 2004. The Quality Assurance Project Plan (QAPP) and sample protocol should be available by the end of April. EPA clarified for the work group that the commitment to a QAPP is part of the MOU, but that the QAPP itself would not be included in the MOU. The QAPP is not negotiated before the MOU is signed, but EPA must approve the QAPP.

An interested party raised a question regarding the initial proposal to use eight existing wells for sampling soils in sludge incorporation areas. 3M stated that, based on EPA comments, it will no longer look at the existing wells but will install eight new wells in the sludge application fields. The interested party asked if soil samples will be taken as the new wells are drilled and 3M said soil samples would be collected during well drilling.

There was some confusion over how 3M would identify where to put monitoring wells. EPA stressed the importance of documenting in the Work Plan how these locations were chosen and what assumptions were made.

An interested party asked how far samples will be taken from the plant outfalls. 3M replied that the samples will be taken five miles downstream and approximately one and a half miles upstream from the plant outfalls.

EPA and other interested parties expressed concern over the removal of small animal sampling from the proposed monitoring program. EPA noted that it had continually stated its interest in understanding the presence of PFOA in the environment and was concerned that the focus of the proposed monitoring program had shifted entirely to human exposure.

There was discussion of the wording 3M and DuPont used to show their commitment to Phase III. EPA stated that its clarifying questions must be included in the MOU in order for EPA to sign.

EPA stated that it did not endorse the decisions of the C8 Assessment of Toxicity Team (CATT) or the Groundwater Investigation Steering Team (GIST), and directed that references to CATT and GIST be removed from the DuPont MOU and Work Plan language to avoid any implication that EPA either endorsed or considered sufficient for EPA's purposes data collected for CATT, GIST, or various State authorities and programs.

V. Identification of Workgroup Next Steps

FMG

- By April 8, 2004, 3M/Dyneon and DuPont will each submit a revised draft Memorandum of Understanding (MOU) to EPA for distribution to and comment by the interested parties. These draft MOUs should include charge, exposure assessment definition, and commitment to Tier III testing. EPA also asked that these next drafts of the MOUs include EPA's clarifying questions.
- 3M/Dyneon will submit a draft Work Plan by April 6, 2004.
- Companies that have not yet submitted complete information on the chemicals to be tested for the incineration ECA will submit that information.

Upcoming Meetings

- The Fluoropolymer Monitoring Subgroup will meet on Wednesday, April 21, 2004 to discuss the DuPont Work Plan.
- The Fluoropolymer Monitoring Subgroup will meet on Thursday, April 29, 2004 to discuss the revised draft MOUs and the 3M/Dyneon Work Plan.
- The next series of Technical Workgroup meetings combined with a Plenary session was scheduled for Tuesday through Thursday, June 22-24, 2004. The Plenary will be held on Thursday, June 24, 2004, from 1:00 to 4:00 PM in Room 1153 of the EPA East Building, 1201 Constitution Avenue, NW, Washington, DC. The determination of which Workgroup will meet on which day, together with the location of the Workgroup meetings, is yet to be arranged. Information on those meetings will be provided as it becomes available.

ECA For The Laboratory-scale Incineration Testing Of Fluoropolymers

March 31, 2004

2005 MAR 18 PM 3:00

RECEIVED
OPPT NCIC

CONTAIN NO CBI

RECEIVED
OPPT CBIC
05 MAR 22 PM 3:02

5

284707

MR 284817

Incineration ECA Drafting Committee

- Bill Beers*
- John Blouin
- Greg Fritz
- Robert Giraud
- Steve Korzeniewski*
- David Menotti
- Rich Leukroth

* Telomers only

Drafting Committee Activities

- ✓ February: Completed the Final Draft ECA Resolved all but one issue during February
- ✓ Continued discussions re: Appendix F clarification / work-around
- ✓ March 2, 2004 Final Draft ECA sent to IPs for required 4 week public comment period
- ✓ Comment period ended 3/30/04

Public Comments on the ECA

- To date no written comments on the ECA were submitted to the docket
- Several comments received from an IP, Drafting Committee members, EPA staff, Dayton Lab:
 - Clarification correction to text in Appendix A.1
 - Clarification of modifications listed in Appendix B.1
 - Clarification to procedure in Appendix C.1
 - Modification to data reporting text in Appendix D.1
 - Typos and punctuation

Appendix F

- No public comments received
- Drafting Committee developed a mutually acceptable work-around that:
 - Changes footnotes in Table 1 such that the Companies would not be obligated to begin testing until after EPA accepts the QAPP
 - This change obviates the need for Appendix F

Conclusion - Action Item

It appears that the Drafting Committee has completed its charge to develop an ECA for incineration testing of fluoropolymers.

Does the Fluoropolymer Technical

Workgroup recommend to the Plenary that the Final Draft ECA be executed by EPA?

ECA Scheduling Next Steps

- Recommendation forwarded to Plenary
- EPA staff prepares ECA signature sets
- Companies sign respective copies
- EPA signs the ECA
- Federal Register Notice announces the ECA and starts the clock for testing to begin (June timeframe)

RECEIVED
DPPT/CBIC

05 MAR 22 PM 3:02

Fluoropolymer Technical Work Group

Incineration Test Protocol Outline

September 17, 2003

CONTAIN NO CBI

2005 MAR 18 PM 3:08

RECEIVED
DPPT/CBIC

28482

12

(3)

Discussion Objective

- Review test protocol outline for understanding
- Determine next steps

9/17/03

presentation to
Fluoropolymer Technical Work Group

Outline

1. Introduction
 2. Test Objective
 3. Experimental Approach
 4. Materials and Methods
 5. Combustion Test Sampling and Analysis
 6. Reporting of Results
- Appendix

9/17/03

presentation to
Fluoropolymer Technical Work Group

3

14

Introduction

- Overall objective of test program is to determine if incineration of fluoropolymers is a potential source of PFOA to the environment
- Submission was an outline as agreed; additional detail to be developed pending agreement on outline
- QAPP addressing QA/QC to be developed as well

9/17/03

Presentation to
Fluoropolymer Technical Work Group

Research Program

- Much work needed to integrate sampling & analytical methods for PFOA into an incineration experimental program
- Initial focus will be on demonstrating proposed methods are capable of meeting data quality objectives (DQOs)
- Need provision to obtain approval to modify test program if do not appear able to provide information meeting DQOs

9/17/03

presentation to
Fluoropolymer Technical Work Group

Test Objective

- Investigate incineration of fluoropolymers under laboratory-scale conditions representative of typical municipal waste combustor operations in the U.S. to quantitatively determine potential emission levels of PFOA

9/17/03

Presentation to
Fluoropolymer Technical Work Group

Experimental Approach

- Conduct elemental analysis of test feeds to define stoichiometry
- Perform TGA to inform conditions for test material gasification in combustion tests
- Verify quantitative transport of PFOA
- Conduct combustion tests

9/17/03

presentation to
Fluoropolymer Technical Work Group

Combustion Test Materials & Methods


Test Feed	Dry melt resin composite	PTFE composite	Fluoro-elastomer composite	Aqueous dispersion composite
Temperature	900 °C	900 °C	900 °C	900 °C
Residence Time	2 sec	2 sec	2 sec	2 sec
Excess O ₂	10 %	10 %	10 %	10 %
No. of runs	3	3	3	3
No. of thermal blanks	≥1	≥1	≥1	≥1

Note: planned temperature reflects low end of typical MWC operations

9/17/03

presentation to
Fluoropolymer Technical Work Group

Advanced Thermal Reactor System



presentation to
Fluoropolymer Technical Work Group

9/17/03

Combustion Test Sampling & Analysis

- Exhaust Gas
 - Monitored parameters (CO, CO₂, O₂, flow)
 - Sampling
 - Aqueous solution bubblers planned
 - Analysis
 - Fluoride ion (total inorganic fluorine) via ion-selective electrode or ion chromatography
 - Total fluorine via Wickbold torch
 - Total organic fluorine by difference (between Total fluorine and Total inorganic fluorine)
 - PFOA via LC/MS/MS

9/17/03

presentation to
Fluoropolymer Technical Work Group

10

Combustion Test Sampling & Analysis

- Test Material Composites
 - Elemental analysis (C, H, N, F, S, O)
 - Note: for these materials, total organic fluorine is equivalent to total fluorine

9/17/03

presentation to
Fluoropolymer Technical Work Group

Reporting of Results

- Exhaust Gas Results
- Test Material Results
- Exposure Assessment

9/17/03

presentation to
Fluoropolymer Technical Work Group

12

Discuss Next Steps

2

9/17/03

presentation to
Fluoropolymer Technical Work Group

13

Detailed Test Protocol Outline

Proposal, September 12, 2003

1. Introduction

The overall goal of this program is to determine if incineration of fluoropolymers (in applications where incineration is a commonly used disposal practice) is a potential source of PFOA to the environment.

This document presents a detailed outline of a protocol for a research program to conduct incineration testing. Substantial preparatory work is necessary to integrate available sampling and analytical methods for PFOA into an experimental program for incineration testing.

Following agreement on this document, a test protocol and Quality Assurance Project Plan (QAPP) can be prepared. The QAPP will include data quality objectives (DQOs). Although alternative methods are included herein to the extent practicable, it is anticipated that the administration of this program will allow for obtaining approval to modify the test program (e.g., to substitute alternate test methods) in case(s) where proposed method(s) do not appear able to provide information meeting these DQOs.

The QAPP will also address other quality assurance/quality control elements for this test program, including project organization, chain of custody, and sample container selection.

Details of this test protocol are outlined in subsequent sections. The test objective is presented in Section 2. Section 3 discusses the overall experimental approach and preliminary testing prior to the combustion tests. Section 4 presents the materials and methods involved in this test program with focus on combustion testing. Plans for sampling and analysis are described in Section 5. Section 6 reviews how results of this program will be reported.

2. Test Objective

The specific objective of this test program is to investigate incineration of designated fluoropolymers under laboratory-scale conditions representative of typical

municipal waste combustor operations in the U.S. to quantitatively determine emission levels of PFOA.

3. Experimental Approach

Each test material (as described in Section 4.2) will undergo elemental analysis (see Section 5.2) to define the basic parameters for stoichiometric calculations.

Thermogravimetric analysis (TGA) per ASTM E1641 will be conducted to determine the gasification temperature of each test material. TGA will be performed on each sample to determine the temperature range required for gasification of the sample and ash content. This analysis will be conducted in flowing air from room temperature to 1000°C at 25°C/minute using 3 to 5 mg samples. The temperature for 100% gasification for each test material will be considered in establishing conditions for the gasification section (pyroprobe section) of the experimental apparatus for the combustion tests; see section 4.3.

Overall, stoichiometry and TGA results will form the basis for setting experimental conditions (e.g., time and temperature) in the gasification section of the experimental system during the combustion tests.

Combustion tests will be carried out at specified operating conditions as presented in Section 4.3.

Prior to combustion testing, quantitative transport of PFOA will be verified. For these transport tests, plans call for gasifying nominally 1 mg of PFOA at 150 to 200 °C with transfer line and reactor temperatures nominally 30 to 50 °C higher than the gasification temperature. The exhaust gas will be sampled and analyzed as described in Section 5.1.4 to determine quantitation of PFOA. If the PFOA transport efficiency is found to be less than a specified level (e.g., 70%), then the reactor would be disassembled and extracted with an appropriate solvent (e.g., methanol). This solvent sample would be analyzed via the analytical method described in Section 5.1.4 to determine if adsorption on the reactor walls is responsible for the low recovery. The experimental apparatus described in Section 4.1 is configured such that additional extractions of the transfer lines between the pyroprobe and the reactor and

between the reactor and the downstream sampling point are not feasible.


4. Materials and Methods

4.1 Combustion Test Experimental Apparatus

Incineration testing is to be accomplished using a batch-charged continuous flow reactor system. The test sample is gasified and transported to a high temperature reactor. In the high temperature reactor, the sample vapors are subjected to controlled conditions of residence time, temperature, and excess air. Combustion products are collected for quantitative analysis.

Use of the Advanced Thermal Reactor System (ATRS) at the University of Dayton Research Institute (UDRI) is planned. A schematic of the ATRS as planned for use in this test program is presented in Figure 1.

Figure 1. Schematic of ATRS for Planned Testing



Supplemental gas flow and main gas flow refer to the planned gas feeds (synthetic air and methane).

The ATRS consists of a reactor assembly and in-line gas chromatograph/detector system connected via a cryogenic interface. The reactor assembly consists of a thermally insulated enclosure housing the sample introduction, reactor, and transfer line systems. Sample introduction for solid materials employs a pyroprobe, a device designed to gasify samples by heating them at a fixed rate. During combustion tests, the transfer line between the pyroprobe and the reactor is heated and maintained above 250 °C. The reactor is housed within its own small tube furnace and may be independently heated to as high as 1200 °C. (Actual conditions planned for this test program are presented in Section 4.3.) The exhaust line from the reactor is heat traced to prevent cool regions where reactor products could otherwise be lost through condensation. The cryogenic interface (cold trap) is of a shell and tube design and provides significant cooling of the combustion exhaust gas prior to on-line monitoring or sample collection.

For this test program, plans call for setting the cold trap temperature at nominally -15 °C to be below the freezing point of water (H₂O) but above the sublimation temperature of carbon dioxide (CO₂) to assist in separating H₂O from carbon monoxide (CO) and CO₂.

The in-line gas chromatograph (with molecular sieve column) and mass selective detector (MSD) are planned to be used to monitor CO and CO₂. Exhaust gas samples for off-line analysis will be collected from the vent line off the cold trap; see Section 5.1.

4.2 Test Materials

Four test materials are planned for this study. Each will be a composite mixture of representative fluoropolymers, as solids, in equal proportions across producers for each of the following four classes:

- Dry melt resins (FEP, PFA, THV, ETFE, HTE)
- PTFE
- Fluoroelastomers
- Aqueous dispersions (PTFE, FEP, PFA, THV)

4.3 Combustion Test Experimental Conditions

The test materials described in Section 4.2 will be subjected to laboratory-scale incineration using the experimental apparatus described in Section 4.1.

Synthetic air (mixture of 21% oxygen and 79 % nitrogen) will be used in place of compressed air to prevent potential interference in the experimental system due to background levels of CO₂ in compressed air.

Methane will be used as needed as a supplemental fuel to ensure the presence of sufficient hydrogen to convert fluorine to hydrogen fluoride (HF).

The planned operating conditions for the high temperature reactor during the combustion tests are 900 °C with 2 seconds gas residence time and 10% oxygen in the exhaust gas. As the Appendix indicates, these conditions are representative of typical operating conditions for the high temperature zone of municipal waste combustors (MWCs) in the U.S., except that the planned temperature reflects the low end of normal MWC operating temperatures. Also, as the information in the Appendix indicates, the planned temperature is less than typical secondary chamber operating temperatures for medical waste incinerators in the U.S.

As noted in Table 1, three replicates are planned for each test level (combination of test material and temperature).

Table 1

Test Material	Dry melt resin composite	PTFE composite	Fluoroelastomer composite	Aqueous dispersion composite
Temperature	900 °C	900 °C	900 °C	900 °C
No. of runs	3	3	3	3

Additionally, at least one thermal blank (with combustion test feeds except for the test material) is planned for each group of 3 runs.

The amount of test material fed will be large enough to assure ability to detect PFOA in the emissions, but small enough to assure sufficient excess oxygen to be representative of typical MWC conditions. While elemental analysis and TGA is required to establish the planned mass

of sample, the expected sample size is on the order of 1 to 2 mg.

The temperature in the pyroprobe section will be maintained at approximately 50 to 100 °C above the highest temperature for 100% gasification across the test materials as determined from the thermogravimetric experiments earlier in the test program. This is necessary to assure complete gasification of the sample of test material and a common set of experimental conditions across the test materials during combustion testing.

5. Combustion Test Sampling and Analysis

5.1 Exhaust Gas Sampling & Analysis

Gas samples for off-line analysis will be collected from a vent line off the cold trap and may be subjected to additional external cooling (e.g., ice bath) as needed.

Analysis of the exhaust gas samples of the thermal blanks will focus on PFOA since the primary purpose of conducting these blank runs is to check for possible cross-contamination between sample runs.

5.1.1 Monitored Parameters

As noted in Section 4.1, on-line monitoring for CO and CO₂ via the in-line GC using a molecular sieve column and MSD is planned. Alternately, Tedlar® bag samples of exhaust gas may be collected for off-line CO and CO₂ analysis.

Exhaust gas flow rate will be monitored based on measured input flow rates of the synthetic air and methane gas feeds. Exhaust gas oxygen concentration will be calculated, based on measured input flow rate of synthetic air and methane assuming complete combustion.

5.1.2. Fluoride

The exhaust gas will be sampled and analyzed for fluoride ion to assist in performing a fluoride balance across the experimental system.

Fluoride ion will be sampled via absorption into aqueous solution, using bubblers (low pressure drop midget

impingers) in series. As Figure 1 indicates, initial plans call for using three bubblers in series with the first one empty to serve as a knock-out pot and the second and third containing a predetermined amount of aqueous solution. (The number of aqueous solution bubblers will be adjusted as necessary.) Upon completion of sample collection, the amounts in each bubbler will be measured and the contents of the bubblers will be quantitatively transferred into a container for subsequent analysis for total inorganic fluorine (i.e., fluoride ion) via ion chromatography or ion selective electrode.

5.1.3 Total Fluorine

The aqueous solution sample collected as described in Section 5.1.2 is also planned to be subjected to analysis for total fluorine via Wickbold torch so that total organic fluorine can be determined by difference between total fluorine and total inorganic fluorine. Work is in progress to confirm that detection limits for total fluorine analysis via Wickbold torch are low enough to be informative for this test system.

5.1.4 PFOA

Exhaust gas samples will be analyzed for PFOA via LC/MS/MS at a qualified commercial laboratory operating under suitable data quality guidelines.

Development is in progress to define the most suitable sampling technique for PFOA in the incineration exhaust gas.

Initial plans call for using the aqueous solution bubblers described in Section 5.1.2 to collect PFOA from the exhaust gas and for sending a portion of the aqueous solution for PFOA analysis as described above. Additionally, an attempt will be made to use an OSHA Versatile Sampler (OVS) as a back-up sampling device. If OVS is also used to sample PFOA in the exhaust gas, then the OVS would also be sent for off-line LC/MS/MS analysis to quantify PFOA as a cross-check on the aqueous solution bubbler results.

5.2 Test Material Sampling & Analysis

Each test material composite will undergo elemental analysis for carbon, hydrogen, nitrogen, fluorine, sulfur,

and oxygen by difference. Ultimate analysis (ASTM D3176 and other ASTM methods referenced therein) are planned for this analysis. Moisture is also determined by this method. Depending on sample size, it may be necessary to implement the microanalytic analog of ultimate analysis.

Based on process knowledge, the level of total fluorine in the test materials is orders of magnitude higher than the potential level of inorganic fluoride in these materials. Therefore, for this test program, plans call for assuming that the total organic fluorine value for each test material composite is the same as the fluorine value determined via elemental analysis as described above.

6. Reporting of Results

6.1 Exhaust Gas Results

6.1.1 Monitored Parameters

CO will be reported in terms of parts per million by volume (ppmv). CO₂ will be reported in terms of percent by volume (%). Oxygen will be reported in terms of percent by volume (%). Exhaust gas flowrate will be reported in units of cubic centimeters per minute (cm³/min).

6.1.2 Fluoride and Fluorine

Total fluorine and fluoride (total inorganic fluorine) in the exhaust gas will each be reported in terms of concentration (mass of fluorine per volume of exhaust gas) in the gas as well as on the basis of mass of fluorine per mass of starting test material.

Total organic fluorine will be determined by difference between total fluorine and total inorganic fluorine.

6.1.3 PFOA

PFOA in the exhaust gas will be reported in terms of concentration in the gas as well as on the basis of mass per mass of starting test material.

6.2 Test Material Results

Elemental compositions will be reported in terms of mass per mass of composite feed material.

6.3 Exposure Assessment

In the event that PFOA is found in the exhaust gas at a concentration above the limit of quantitation (for the matrix) from one or more experiments described in this protocol, then the potential for exposure related to incineration of the subject material will be assessed to inform the basis for possible next steps.

This assessment will consider a number of factors such as

- Test program-determined PFOA emission factor,
- estimated amounts of subject material in feed to full-scale waste incinerators, and
- degree of post-combustion air pollution control (e.g., use and effectiveness of carbon adsorption).

Appendix

Polymers of the sort being investigated in this test program may be present at trace to low concentrations in municipal solid waste or in medical waste and therefore may be incinerated.

A.1 Types of Incinerators

A.1.1 Municipal Waste Combustors

According to the Integrated Waste Services Association (IWSA), there are a total of 98 waste-to-energy facilities operating municipal waste combustors (MWCs) in the U.S. as of 2002. (IWSA 2002) Table A-1 summarizes the number and annual capacity of these units by type of technology employed.

Table A-1. MWCs in 2002

Type	Number of Facilities	Annual Capacity (million Ton/year)
Mass Burn	68	22.5
Refused Derived Fuel (RDF)	18	6.4
Modular	12	0.5
Total	98	29.4

As the capacity values indicate, modular units are generally small MWCs accounting for less than a total of 2% of the municipal solid waste incinerated in the U.S. in 2002.

A.1.2 Hospital/Medical/Infectious Waste Incinerators

Although earlier reports indicated over 2200 medical waste incinerators in the U.S. in the 1990s (EPA 2000a), the current EPA Office of Air Quality, Planning, and Standards (OAQPS) inventory indicates that there are 116 hospital/medical/ infectious waste incinerators (HMIWIs) in the U.S. as of July 28, 2003. (EPA 2003)

This represents a greater than 90% reduction in the number of operating HMIWIs in the U.S. Many medical waste incinerators were closed rather than upgraded to meet new emission standards, as hospitals improved their programs to segregate infectious ("red bag") waste burned in HMIWIs

from non-infectious ("black bag") waste handled as municipal solid waste after it leaves the hospital.

A.2 Operating Conditions

As noted by EPA, many incinerators for municipal solid waste are designed to operate in the combustion zone at 1800°F [982°C] to 2000°F [1093°C] to ensure good combustion. (EPA 1995) EPA new source performance standards (NSPS) and emission guidelines for both municipal waste combustors (MWCs) and hospital/medical/infectious waste incinerators (HMIWIs) are based on the use of "good combustion practices" (GCP). (EPA 1997, EPA 2000b, EPA 2000c, Van Remmen 1998)

Speaking of MWCs, Donnelly notes, "Design of modern efficient combustors is such that there is adequate turbulence in the flue gas to ensure good mixing, a high-temperature zone (greater than 1000 °C) to complete burnout, and long enough residence time at high temperature (1-2 sec) for complete burnout." (Donnelly 2000) The term "flue gas" here refers to the gas above the grate.

With respect to HMIWIs, Van Remmen states "any unit which presently [prior to compliance date] has a [secondary chamber] residence time less than two seconds at 1000 °C does not meet the requirement for good combustion under the new regulations." (Van Remmen 1998)

Similarly, most MWCs are expected to typically operate with a 2 second gas residence time in the high temperature zone in order to assure compliance with emission standards on carbon monoxide and dioxins.

A.2.1 MWC Operating Conditions

EPA presents operating data for some MWCs in "Municipal Waste Combustion Assessment: Technical Basis for Good Combustion Practice" and points the reader elsewhere for additional data on specific representative MWCs.

Modular MWC

Specifically, this background document (EPA 1989) includes secondary chamber temperatures for modular MWCs that had CO emission levels less than current emission standards, and these are summarized in Table A-2.

Table A-2. Modular MWC Temperatures

Secondary Chamber Temperature (°C)	Oswego Co., NY	Red Wing, MN
Start of campaign	1012	
End of campaign	995	
Low secondary temperature	885	

As highlighted in Table A-2, typical secondary chamber temperatures for these dual-chamber modular units are in the range of 951 to 1071 °C.

As indicated in section A.1, such modular units are generally small MWCs and account for less than a total of 2% of the municipal solid waste incinerated in the U.S.

Although this 1989 EPA background document does not present temperature data for mass burn nor RDF units, reports from the National Incinerator Testing and Evaluation Program (NITEP) present operating data for an RDF combustor (Mid-Connecticut) and for a mass burn waterwall combustor (Quebec City) otherwise discussed in the 1989 background document.

RDF MWC

Furnace temperatures and flue gas oxygen levels for Mid-Connecticut RDF combustor performance tests operating under good combustion conditions across a range of steam loads (Finklestein and Klicius 1994) are summarized in Table A-3.

Table A-3. RDF MWC - Mid-Connecticut

Steam load	Low	low	Inter- mediate	Inter- mediate	normal	normal	normal	high
test number	PT-13	PT-14	PT-10	PT-02	PT-09	PT-08	PT-11	PT-12
Furnace temperature (°C)	965	1004	1012	1022	1033	1015	1026	1049
flue gas O ₂ (%)	10.1	9.6	9.2	9.1	7.6	7.5	7.9	6.4

The average operating conditions for this RDF unit across the range of steam loads are 1016 °C and 8.4% O₂.

Mass Burn MWC

Furnace temperatures (average of front and rear radiation chamber temperatures) and flue gas oxygen levels (dry basis) for Quebec City mass burn combustor performance tests operating under good combustion conditions across a

range of steam loads (Environment Canada 1988) are summarized in Table A-4.

Table A-4. Mass Burn MWC - Quebec City

Steam load	Low	low	Low	design	design	Design	High	high
test number	PT02	PT10	PT11	PT05	PT06	PT12	PT07	PT09
Furnace temperature (°C)	849	875	869	1014	1030	992	1085	1006
flue gas O ₂ (dry)	13	13	12	9	9	10	10	10

The average operating conditions for this mass burn unit across the range of steam loads are 965 °C and 10.8% O₂. When operated at design steam load, the average operating conditions for this mass burn MWC are 1012 °C and 9.3% O₂.

MWC Summary

Considering the relative quantities of municipal waste burned annually in each type of MWC and the data in this section, average typical operating conditions for the high temperature zone of MWCs are nominally 1000 °C and 10% O₂.

A.2.2 HMIWI Operating Conditions

EPA notes that over 97% of medical waste incinerators are controlled air modular units (EPA 2000a). Recent communication with EPA OAQPS indicates that virtually all existing HMIWIs are controlled air modular (two-chamber) units.

Theodore reports the range of temperatures for the secondary chamber of controlled air medical waste incinerators as 980 to 1200 °C. (Theodore 1990) EPA notes that auxiliary fuel (e.g., natural gas) is burned in the secondary chamber of medical waste incinerators to sustain temperatures in the range of 985 to 1095 °C and that combustion air at 100 to 300 % in excess of the stoichiometric requirement is usually added to the secondary chamber. (EPA 2000a)

As noted above, a more recent report indicates that existing HMIWIs operate with secondary chamber temperatures greater than or equal to 1000 °C with a gas residence of 2 seconds. (Van Remmen 1998)

References

Donnelly, J.R. Waste Incineration Sources: Municipal Waste Combustion. In: W.T., ed., Air Pollution Engineering Manual, 2nd edition. Air and Waste Management Association. New York, NY: Van Nostrand Reinhold, 2000, pp 257-268.

Environment Canada. National Incinerator Testing and Evaluation Program: Environmental Characterization of Mass Burning Incinerator Technology at Quebec City - Summary Report, EPS 3/UP/5, June 1988.

Environmental Protection Agency (EPA). Municipal Waste Combustion Assessment: Technical Basis for Good Combustion Practice, EPA 600/8-89-063, August 1989.

EPA. Emission Factor Documentation for AP-42 Section 2.1, Refuse Combustion, May 1993.

EPA. Decision Maker's Guide to Solid Waste Management, Volume II, Chapter 8, 1995.

EPA. Standards of Performance for New Stationary Sources and Emission Guidelines for Existing Sources: Hospital/Medical/Infectious Waste Incinerators, 62 Federal Register 48346, September 15, 1997.

EPA. Exposure and Human Health Reassessment of 2,3,7,8-Tetrachlorodibenzo-p-Dioxin (TCDD) and Related Compounds, Part I: Estimating Exposure to Dioxin-Like Compounds Volume 2: Sources of Dioxin-Like Compounds in the United States, Chapter 3, EPA/600/P-00/001Bb, Draft Final Report, September 2000.

EPA. New Source Performance Standards for New Small Municipal Waste Combustion Units, 65 Federal Register 76350, December 6, 2000.

EPA. Emission Guidelines for Existing Small Municipal Waste Combustion Units, 65 Federal Register 76378, December 6, 2000.

EPA. HMIWI Facility and Emissions Inventory, draft, July 28, 2003,
www.epa.gov/ttnatw01/129/hmiwi/2003hmiwi_inventory.xls

Finklestein, A. and R. D. Klicius. National Incinerator Testing and Evaluation Program: The Environmental Characterization of Refuse-derived Fuel (RDF) Combustion Technology, Mid-Connecticut Facility, Hartford, Connecticut, EPA-600/R-94-140 (NTIS PB96-153432), December 1994.

Integrated Waste Services Association (IWSA). The 2002 IWSA Directory of Waste-to-Energy Plants, 2002, www.wte.org/2002_directory/IWSA_2002_Directory.html

Theodore, L. Air Pollution Control and Waste Incineration for Hospitals and Other Medical Facilities, Van Nostrand Reinhold, New York, 1990, pp 313-320.

Van Remmen, T. Evaluation of the available air pollution control technologies for achievement of the MACT requirements in the newly implemented new source performance standards (NSPS) and emission guidelines (EG) for hospital and medical/infectious waste incinerators, Waste Management, 1998, Vol. 18, pp 393-402